



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2130**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/3/26*  
*Time: 2:30 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/6/26*  
*Time: 9:30 AM*  
*Analyst: AS*

*Facility Name: Community Swim Club*

*Address: 106 Aqua Drive*  
*Pittsburgh, PA 15238*

*Matrix: Recreational Water*

*Source Type: Baby Pool*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation</b> | <b>Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-------------------|------------------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/4/26            | 9:25 AM          | MD             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/4/26            | 9:25 AM          | MD             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/3/26            | 4:40 PM          | AS             | SM 9215B      |
| <b>Field Analysis</b>      | <b>Results</b> | <b>Reporting limit</b> |                   | <b>Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
| pH:                        | 7.4 SU         | 7.2 - 7.8 SU           | 8/3/26            | 2:30 PM          | LL             | DPD           |
| Chlorine:                  | 3.0 mg/l       | 1.0 - 5.0 mg/l         | 8/3/26            | 2:30 PM          | LL             | DPD           |
| Turbidity:                 | 1 NTU          | 1 - 2 NTU              | 8/3/26            | 2:30 PM          | LL             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor