



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2002**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*                      *Eastside Bond*

*Address:*                              *6015 Spirit St.*  
Pittsburgh, PA 15206

*Matrix:*                                *Recreational Water*

*Source Type:*                        *Pool*

**Sample Collection**

*Date:*                                      *7/28/26*

*Time:*                                     *2:30 PM*

*Method:*                                *Grab*

**Sample Final Analysis**

*Date:*                                      *7/31/26*

*Time:*                                     *10:00 AM*

*Analyst:*                                 *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 7/29/26                     | 9:50 AM | MD             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 7/29/26                     | 9:50 AM | MD             | SM 9222B      |
| Standard plate count:      | 100/ml         | 200/ml                 | 7/28/26                     | 5:00 PM | AH             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.6 SU         | 7.2 - 7.8 SU           | 7/28/26          | 2:30 PM | EG             | DPD           |
| Chlorine:             | 3.0 mg/l       | 1.0 - 5.0 mg/l         | 7/28/26          | 2:30 PM | EG             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 7/28/26          | 2:30 PM | EG             | Visual        |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)