



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2375**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *OakHill - Wadsworth*

*Address:*              *480 Oak Hill Dr*  
*Pittsburgh, Pa 15213*

*Matrix:*                *Recreational Water*

*Source Type:*        *Pool*

**Sample Collection**

*Date:*                    *8/4/26*

*Time:*                  *9:45 AM*

*Method:*              *Grab*

**Sample Final Analysis**

*Date:*                    *8/7/26*

*Time:*                  *12:00 PM*

*Analyst:*                *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation</b> | <b>Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-------------------|------------------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/5/26            | 11:30 AM         | MD             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/5/26            | 11:30 AM         | MD             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/4/26            | 5:00 PM          | AS             | SM 9215B      |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst | Method |        |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 8/4/26    | 9:45 AM | JT     | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/4/26    | 9:45 AM | JT     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/4/26    | 9:45 AM | JT     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor