



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2272

Customer

Facility Name: Homewood
Address: 540 N. Lang Ave.
Pittsburgh, PA 15208

Sample Collection

Date: 8/5/26
Time: 11:30 AM
Method: Grab

Matrix: Recreational Water
Source Type: Shallow End

Sample Final Analysis

Date: 8/8/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/26 8:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/26 8:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/26 5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/5/26 11:30 AM	WB	DPD
Chlorine:	4.5 mg/l	1.0 - 5.0 mg/l	8/5/26 11:30 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/26 11:30 AM	WB	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)