



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 045

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water
Source Type: Pool Deep

Sample Collection

Date: 8/3/26
Time: 9:54 AM
Method: Grab

Sample Final Analysis

Date: 8/6/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	8/4/26	8:50 AM	MD	SM 9222G
Total coliforms:	0/100mls	A	8/4/26	8:50 AM	MD	SM 9222B
Standard plate count:	5700/ml	E	8/3/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	8.0 SU	E	8/3/26	9:54 AM	JT	DPD
Chlorine:	0.0 mg/l	E	8/3/26	9:54 AM	JT	DPD
Turbidity:	1 NTU	A	8/3/26	9:54 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)