



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2628

Customer

Facility Name: Buena Vista Fire Company

Address: 3333 Fire Station St.
Buena Vista, PA 15018

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/7/26

Time: 3:40 PM

Method: Grab

Sample Final Analysis

Date: 7/9/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	10:05 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	10:05 AM	MD	SM 9222B
Standard plate count:	25/ml	200/ml	7/7/26	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/26	3:40 PM	LL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/26	3:40 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	3:40 PM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor