



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 120

Customer

Facility Name: Wingate
Address: 210 Executive Drive
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/8/26
Time: 11:15 AM
Method: Grab

Sample Final Analysis

Date: 7/10/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/26	2:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/26	2:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/26	6:10 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/9/26	9:30 AM	MD	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/26	11:15 AM	EG	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/26	11:15 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/26	11:15 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)