



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 2709

Customer

Facility Name: District
Address: 1759 Waterfront Pl
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/6/26
Time: 10:25 AM
Method: Grab

Sample Final Analysis

Date: 7/8/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	12:00 PM	MH	SM 9222G
Total coliforms:	30/100mls	2/100mls	7/7/26	12:00 PM	MH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/6/26	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/6/26	10:25 AM	JB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/6/26	10:25 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	10:25 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor