



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 109**

**Customer**

**Facility Name:** Gateway High School  
**Address:** 3000 Gateway Campus Blvd.  
Monroeville, PA 15146

**Sample Collection**

**Date:** 7/7/26  
**Time:** 10:05 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Shallow End

**Sample Final Analysis**

**Date:** 7/9/26  
**Time:** 11:30 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/8/26               | 11:05 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/8/26               | 11:05 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/7/26               | 7:00 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/7/26    | 10:05 AM | DW      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/7/26    | 10:05 AM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/7/26    | 10:05 AM | DW      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)