



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 129

Customer

Facility Name: Hampton Inn Belle Vernon

Address: 1525 Broad Ave Ext
Belle Vernon, PA 15012

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/6/26

Time: 11:40 AM

Method: Grab

Sample Final Analysis

Date: 7/8/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26 12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26 12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/6/26 6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/6/26 11:40 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/6/26 11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26 11:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)