



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2257

Customer

Facility Name: Highland Park Club
Address: 1001 N. Negley Ave.
Pittsburgh, PA 15206

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/7/26
Time: 3:45 PM
Method: Grab

Sample Final Analysis

Date: 7/9/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	9:35 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	9:35 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/26	3:45 PM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/26	3:45 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	3:45 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor