



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 461**

**Customer**

**Facility Name:** *Holiday Inn*  
**Address:** *105 Stone Quarry Rd.*  
*Monaca, PA 15061*

**Sample Collection**

**Date:** *7/6/26*  
**Time:** *12:35 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/8/26*  
**Time:** *12:30 PM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/7/26               | 12:00 PM | MH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/7/26               | 12:00 PM | MH      | SM 9222B |
| Standard plate count: | 5700/ml  | 200/ml          | 7/6/26               | 6:25 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 7/6/26    | 12:35 PM | AMH     | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 7/6/26    | 12:35 PM | AMH     | DPD    |
| Turbidity:     | 3 NTU    | 1 - 2 NTU       | 7/6/26    | 12:35 PM | AMH     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor