



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2366

Customer

Facility Name: Mt Lebanon Rec Cntr

Address: 900 Cedar Boulevard
Pittsburgh, PA 15228

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/6/26

Time: 10:51 AM

Method: Grab

Sample Final Analysis

Date: 7/8/26

Time: 1:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	12:30 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26	12:30 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/6/26	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	7/6/26	10:51 AM	SL	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/6/26	10:51 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	10:51 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor