



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2402

Customer

Facility Name: *Pgh Golf Club*

Address: *5280 Northumberland St.
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool- Shallow*

Sample Collection

Date: *7/7/26*

Time: *2:32 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/9/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	9:35 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	9:35 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/26	2:32 PM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/26	2:32 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	2:32 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor