



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2458

Customer

Facility Name: Sandcastles Water Park

Address: 1000 Sandcastle Drive
Homestead, PA 15120

Matrix: Recreational Water

Source Type: 1 Landing Pool

Sample Collection

Date: 7/7/26

Time: 3:40 PM

Method: Grab

Sample Final Analysis

Date: 7/9/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	10:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	10:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/7/26	3:40 PM	AHV	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/7/26	3:40 PM	AHV	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	3:40 PM	AHV	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)