



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 439

Customer

Facility Name: Seneca Valley H.S.

Address: 128 Seneca School Rd.
Harmony, PA 16037

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/8/26

Time: 1:39 PM

Method: Grab

Sample Final Analysis

Date: 7/10/26

Time: 2:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/26	2:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/26	2:00 PM	SL	SM 9222B
Standard plate count:	570/ml	200/ml	7/8/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/8/26	1:39 PM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/8/26	1:39 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/26	1:39 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor