



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2509

Customer

Facility Name: Staunton
Address: 1501 Staunton Drive
Moon Township, PA 15108

Sample Collection

Date: 7/6/26
Time: 9:04 AM
Method: Grab

Sample Final Analysis

Date: 7/8/26
Time: 12:30 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	12:00 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26	12:00 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/6/26	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/6/26	9:04 AM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/6/26	9:04 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	9:04 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)