



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2507

Customer

Facility Name: Stanford Court

Address: 1200 Stanford Ct.
Coraopolis, PA 15108

Sample Collection

Date: 7/8/26
Time: 8:00 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Source Type: Pool

Date: 7/10/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/26	8:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/26	4:00 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/26	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/26	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/26	8:00 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)