



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2524

Customer

Facility Name: Thornberry
Address: 744 Winvue Dr.
Pittsburgh, PA 15205

Sample Collection

Date: 7/8/26
Time: 9:45 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/9/26
Time: 4:00 PM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	3:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	3:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/26	3:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/8/26	9:45 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/26	9:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/26	9:45 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)