



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2435

Customer

Facility Name: Trellis North Fayette
Address: 1500 Park Lane Drive
Pittsburgh, PA 15275

Sample Collection

Date: 7/7/26
Time: 10:44 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 7/9/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	9:05 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	9:05 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/26	10:44 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/7/26	10:44 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	10:44 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)