



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2519

Customer

Facility Name: Sunridge
Address: 1 Sunridge Dr.
Champion, PA 15622

Sample Collection

Date: 7/6/26
Time: 10:47 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/8/26
Time: 11:00 AM
Analyst: AS

Source Type: Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/7/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26	10:30 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	7/6/26	5:00 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/7/26	1:10 PM	AH	SM 9230C
---------------------	----------	----------	--------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	7/6/26	10:47 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/6/26	10:47 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	10:47 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)