



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2584

Customer

Facility Name: Wildwood Golf Club
Address: 2195 Sample Road
Allison Park, PA 15101

Sample Collection

Date: 7/8/26
Time: 9:44 AM
Method: Grab

Matrix: Recreational Water
Source Type: Baby Pool

Sample Final Analysis

Date: 7/10/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/26	9:10 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/26	9:10 AM	MD	SM 9222B
Standard plate count:	100/ml	200/ml	7/8/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/26	9:44 AM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/8/26	9:44 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/26	9:44 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor