



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2560

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Washington Gardens*

Address: *834 Washington Ave.*
Carnegie, PA 15106

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/6/26*

Time: *12:46 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/8/26*

Time: *1:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	12:30 PM	MH	SM 9222G

Total coliforms:	0/100mls	2/100mls	7/7/26	12:30 PM	MH	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	5700/ml	200/ml	7/6/26	6:25 PM	SL	SM 9215B
-----------------------	---------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C
---------------------	----------	----------	--------	----------	---	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	7/6/26	12:46 PM	SL	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/6/26	12:46 PM	SL	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/6/26	12:46 PM	SL	Visual
------------	-------	-----------	--------	----------	----	--------

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)