



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2247**

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Sample Collection**

*Facility Name:*      *Hickory Heights*  
*Address:*      *118 Hickory Heights Dr.*  
                         *Bridgeville, PA 15017*

*Date:*      7/6/26  
*Time:*      9:50 AM  
*Method:*      Grab

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

*Date:*      7/8/26  
*Time:*      10:30 AM  
*Analyst:*      AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/7/26               | 10:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/7/26               | 10:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/6/26               | 4:40 PM  | AH      | SM 9215B |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 7.4 SU   | 7.2 - 7.8 SU    | 7/6/26               | 9:50 AM  | JB      | DPD      |
| Chlorine:             | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/6/26               | 9:50 AM  | JB      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 7/6/26               | 9:50 AM  | JB      | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)