



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2631

Customer

Facility Name: Neville Side HOA
Address: 1900 Cambridge Dr.
Presto, PA 15142

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/6/26
Time: 1:50 PM
Method: Grab

Sample Final Analysis

Date: 7/8/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26	10:00 AM	AH	SM 9222B
Standard plate count:	10/ml	200/ml	7/6/26	4:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	7/6/26	1:50 PM	JB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/6/26	1:50 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	1:50 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor