



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2443

Customer

Facility Name: Riverview

Address: 400 Riverview Ave.
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/6/26

Time: 1:15 PM

Method: Grab

Sample Final Analysis

Date: 7/8/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/7/26	9:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/7/26	9:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/6/26	3:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	6.8 SU	7.2 - 7.8 SU	7/6/26	1:15 PM	WB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/6/26	1:15 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/6/26	1:15 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)