



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2045

Customer

Facility Name: Bloomfield
Address: 408 Ella St.
Pittsburgh, PA 15224

Sample Collection

Date: 7/7/26
Time: 1:45 PM
Method: Grab

Sample Final Analysis

Date: 7/9/26
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	8:30 AM	MD	SM 9222B
Standard plate count:	50/ml	200/ml	7/7/26	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/26	1:45 PM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/7/26	1:45 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	1:45 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)