



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 310

Customer

Facility Name: University Prep Middle School

Address: 3117 Centre Ave.
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 7/6/26

Time: 1:25 PM

Method: Grab

Sample Final Analysis

Date: 7/8/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/7/26	11:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	A	7/7/26	11:00 AM	MH	SM 9222B
Standard plate count:	0/ml	A	7/6/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	7/6/26	1:25 PM	JT	DPD
Chlorine:	3.0 mg/l	A	7/6/26	1:25 PM	JT	DPD
Turbidity:	1 NTU	A	7/6/26	1:25 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)