



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 063

Customer

Facility Name: *Comfort Inn*

Address: *237 Meadowlands Blvd.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *5/12/26*

Time: *11:35 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/14/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/13/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/13/26	10:30 AM	AH	SM 9222B
Standard plate count:	70/ml	200/ml	5/12/26	4:51 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/12/26	11:35 AM	JMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/12/26	11:35 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/12/26	11:35 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor