



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 127

Customer

Facility Name: Hampton Inn & Suites
Address: 200 Technology Dr.
Coal Center, PA 15423

Sample Collection

Date: 5/11/26
Time: 2:10 PM
Method: Grab

Sample Final Analysis

Date: 5/13/26
Time: 10:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:00 AM	SL	SM 9222B
Standard plate count:	570/ml	200/ml	5/11/26	5:07 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	6.8 SU	7.2 - 7.8 SU	5/11/26	2:10 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/11/26	2:10 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	2:10 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor