



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-2

Lab# 281

Customer

Facility Name: South Fayette High School

Address: 3640 Old Oakdale Rd.
MC Donald, PA 15057

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 5/13/26

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 5/14/26

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/13/26	3:36 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/13/26	3:36 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/13/26	3:32 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/13/26	9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/13/26	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/13/26	9:30 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)