



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 201

Customer

Facility Name: L.A. Fitness Bridgeville

Address: 1155 Washington Pike
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/12/26

Time: 9:18 AM

Method: Grab

Sample Final Analysis

Date: 5/14/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/13/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/13/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/12/26	5:12 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/13/26	10:30 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/12/26	9:18 AM	JMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/12/26	9:18 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/12/26	9:18 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor