



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2491

Customer

Facility Name: Sheraton Inn
Address: 1160 Thorn Run Road
Coraopolis, PA 15108

Sample Collection

Date: 5/27/26
Time: 11:58 AM
Method: Grab

Matrix: Sheraton Inn

Source Type: Pool

Sample Final Analysis

Date: 5/29/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/26	5:31 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/27/26	11:58 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/26	11:58 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/26	11:58 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)