



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2694

Customer

Facility Name: Village of Totteridge
Address: 121 Chipperfield
Greensburg, PA 15601

Sample Collection

Date: 5/27/26
Time: 2:40 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 5/29/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/26	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/27/26	2:40 PM	LL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/26	2:40 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/26	2:40 PM	LL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)