



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 2329

Customer

Facility Name: Lot 24
Address: 2404 Railroad St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/25/26
Time: 10:24 AM
Method: Grab

Sample Final Analysis

Date: 5/27/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/26/26	9:12 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/26/26	9:12 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/25/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/25/26	10:24 AM	JMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/25/26	10:24 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/25/26	10:24 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor