



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2063

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Brook Park Swim Club*

Address: *8190 Rochester Rd*
Pittsburgh, PA 15237

Sample Collection

Date: 5/28/26
Time: 9:30 AM
Method: Grab

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Final Analysis

Date: 5/30/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/26 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/26 10:00 AM	AH	SM 9222B
Standard plate count:	10/ml	200/ml	5/28/26 5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/26 9:30 AM	LL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/26 9:30 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/26 9:30 AM	LL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)