



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2172

Customer

Facility Name: Edgeworth Club

Address: 511 East Drive
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/26/26

Time: 12:45 PM

Method: Grab

Sample Final Analysis

Date: 5/28/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/26/26	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/26/26	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	12:45 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor