



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 201**

**Customer**

**Facility Name:** L.A. Fitness Bridgeville

**Address:** 1155 Washington Pike  
Bridgeville, PA 15017

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 5/26/26

**Time:** 12:55 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 5/28/26

**Time:** 2:30 PM

**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |         |         |    |          |
|-------------------|--------|--------|---------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 5/27/26 | 2:00 PM | JC | SM 9222G |
|-------------------|--------|--------|---------|---------|----|----------|

|                  |          |          |         |         |    |          |
|------------------|----------|----------|---------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 5/27/26 | 2:00 PM | JC | SM 9222B |
|------------------|----------|----------|---------|---------|----|----------|

|                       |        |        |         |         |    |          |
|-----------------------|--------|--------|---------|---------|----|----------|
| Standard plate count: | 120/ml | 200/ml | 5/26/26 | 5:50 PM | SL | SM 9215B |
|-----------------------|--------|--------|---------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |         |    |          |
|---------------------|----------|----------|---------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 5/27/26 | 2:30 PM | JC | SM 9230C |
|---------------------|----------|----------|---------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |         |          |    |     |
|-----|--------|--------------|---------|----------|----|-----|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/26/26 | 12:55 PM | JB | DPD |
|-----|--------|--------------|---------|----------|----|-----|

|           |          |                |         |          |    |     |
|-----------|----------|----------------|---------|----------|----|-----|
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 5/26/26 | 12:55 PM | JB | DPD |
|-----------|----------|----------------|---------|----------|----|-----|

|            |       |           |         |          |    |        |
|------------|-------|-----------|---------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/26/26 | 12:55 PM | JB | Visual |
|------------|-------|-----------|---------|----------|----|--------|

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)