



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Pace

Lab# 510

Customer

Facility Name: *Pace Analytical*

Address: *1803 Philadelphia St.*
Indiana, PA 15701

Matrix: *Recreational Water*

Source Type: *Hot 1*

Sample Collection

Date: *5/29/26*

Time: *10:40 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/31/26*

Time: *2:00 PM*

Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/26	4:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/26	4:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/26	4:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/29/26	4:30 PM	AS	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/29/26	10:40 AM	TS	DPD
Chlorine:	N/A	1.0 - 5.0 mg/l	5/29/26	10:40 AM	TS	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/26	10:40 AM	TS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)