



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 242**

**Customer**

**Facility Name:** *Obama High School*  
**Address:** *515 N. Highland Ave*  
*Pittsburgh, PA 15206*

**Matrix:** *Recreational Water*

**Source Type:** *Pool Shallow*

**Sample Collection**

**Date:** *5/26/26*  
**Time:** *10:40 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *5/28/26*  
**Time:** *10:30 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Rating | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|--------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | A      | 5/27/26              | 10:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | A      | 5/27/26              | 10:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | A      | 5/26/26              | 4:00 PM  | AH      | SM 9215B |

| Field Analysis | Results  | Rating | Date/Time |          | Analyst | Method |
|----------------|----------|--------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | A      | 5/26/26   | 10:40 AM | JT      | DPD    |
| Chlorine:      | 3.0 mg/l | A      | 5/26/26   | 10:40 AM | JT      | DPD    |
| Turbidity:     | 1 NTU    | A      | 5/26/26   | 10:40 AM | JT      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)