Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 454

Customer

Facility Name: *Hampton Inn*

Address: *3000 Mosside Blvd.*
Monroeville, PA 15146

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/3/26*
Time: 11:10 AM
Method: *Grab*

Sample Final Analysis

Date: *3/5/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/4/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/4/26	10:00 AM	JC	SM 9222B
Standard plate count:	200/ml	200/ml	3/3/26	5:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/3/26	11:10 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	3/3/26	11:10 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/3/26	11:10 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor