Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 163

Customer		***Sample Collection***	
Facility Name:	*Holiday Inn Express*	*Date:*	*3/2/26*
		Time:	10:02 AM
Address:	*3695 State Route 31*	*Method:*	*Grab*
	Donegal, PA 15628		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/4/26*
		Time:	*10:30 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	3/3/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/3/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/2/26	4:19 PM	SL	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	3/3/26	10:30 AM	SL	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.6 SU	7.2 - 7.8 SU	3/2/26	10:02 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	3/2/26	10:02 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/2/26	10:02 AM	JC	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)