# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-3**

***Lab# 451***

[redacted]

***Customer***

*Facility Name:* *Kiski Area H.S.*

*Address:* *240 Hyde Park Rd.*
*Leechburg, PA 15656*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *3/3/26*
*Time:* 1:39 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *3/5/26*
*Time:* *11:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/4/26 | 11:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/4/26 | 11:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 3/3/26 | 5:15 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 3/3/26 | 1:39 PM | AH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 3/3/26 | 1:39 PM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/3/26 | 1:39 PM | AH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor