Lab ID No. 02-04041

Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

PPS

Lab# 058

Customer		***Sample Collection***	
Facility Name:	*Colfax Elementary*	*Date:*	*3/2/26*
		Time:	10:34 AM
Address:	*2332 Beechwood Blvd.*	*Method:*	*Grab*
	Pittsburgh, PA 15217		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/4/26*
		Time:	*10:30 AM*
Source Type:	*Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	3/3/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	3/3/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	A	3/2/26	5:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	3/2/26	10:34 AM	MM	DPD
Chlorine:	3.0 mg/l	A	3/2/26	10:34 AM	MM	DPD
Turbidity:	1 NTU	A	3/2/26	10:34 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)