



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2773**

**Customer**

American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Sample Collection**

Facility Name: Belmont Park  
Address: 2003 Sabino Dr  
Washington, PA 15301

Date: 7/22/25  
Time: 12:30 PM  
Method: Grab

**Sample Final Analysis**

Matrix: Recreational Water  
Source Type: Pool


Date: 7/25/25  
Time: 10:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/23/25              | 10:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/23/25              | 10:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/22/25              | 3:40 PM  | SL      | SM 9215B |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 7.6 SU   | 7.2 - 7.8 SU    | 7/22/25              | 12:30 PM | GR      | DPD      |
| Chlorine:             | 1.0 mg/l | 1.0 - 5.0 mg/l  | 7/22/25              | 12:30 PM | GR      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 7/22/25              | 12:30 PM | GR      | Visual   |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2773**

**Customer**

American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Sample Collection**

Facility Name: Belmont Park  
Address: 2003 Sabino Dr  
Washington, PA 15301

Date: 7/22/25  
Time: 12:30 PM  
Method: Grab

**Sample Final Analysis**

Matrix: Recreational Water  
Source Type: Pool

Date: 7/25/25  
Time: 10:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/23/25              | 10:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/23/25              | 10:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/22/25              | 3:40 PM  | SL      | SM 9215B |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 7.6 SU   | 7.2 - 7.8 SU    | 7/22/25              | 12:30 PM | GR      | DPD      |
| Chlorine:             | 1.0 mg/l | 1.0 - 5.0 mg/l  | 7/22/25              | 12:30 PM | GR      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 7/22/25              | 12:30 PM | GR      | Visual   |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor