



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM

Lab# 407

Customer

Facility Name: Morrow Park
Address: 5250 Liberty Ave
Pittsburgh, PA 15224

Sample Collection

Date: 5/5/26
Time: 1:22 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 5/8/26
Time: 12:00 PM
Analyst: AS

Source Type: Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26 11:30 AM	JC	SM 9222G

Total coliforms:	0/100mls	2/100mls	5/6/26 11:30 AM	JC	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	1/0/00 5:50 PM	SL	SM 9215B
-----------------------	------	--------	----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/6/26 12:30 PM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/5/26 1:22 PM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/5/26 1:22 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/5/26 1:22 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor