



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 286

Customer

Facility Name: Spring Hill Suites
Address: 223 Federal St.
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/1/26
Time: 4:11 PM
Method: Grab

Sample Final Analysis

Date: 6/3/26
Time: 1:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26 1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26 1:00 PM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	6/1/26 6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/1/26 4:11 PM	JH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/1/26 4:11 PM	JH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26 4:11 PM	JH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor