



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2013

Customer

Facility Name: Alcoma on the Green

Address: 225 Alcoma Blvd.
Penn Hills, PA 15235

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/13/26

Time: 3:05 PM

Method: Grab

Sample Final Analysis

Date: 7/16/26

Time: 1:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	1:05 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	1:05 PM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	7/13/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/13/26	3:05 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/13/26	3:05 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	3:05 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)