



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 087

Customer

Facility Name: Devonshire
Address: 1050 McNeilly Rd.
Pittsburgh, PA 15226

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 7/13/26
Time: 1:39 PM
Method: Grab

Sample Final Analysis

Date: 7/16/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/14/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	6:00 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/14/26	2:40 PM	AH	SM 9230C
---------------------	----------	----------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.5 SU	7.2 - 7.8 SU	7/13/26	1:39 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/13/26	1:39 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	1:39 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)