



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-13**

**Lab# 491**

**Customer**

**Facility Name:** Center for Fitness and Health

**Address:** 800 Plaza Dr. Suite 100  
Bell Vernon. Pa 15012

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/13/26  
**Time:** 9:30 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/16/26  
**Time:** 11:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/14/26              | 10:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/14/26              | 10:30 AM | AH      | SM 9222B |
| Standard plate count: | 5700/ml  | 200/ml          | 7/13/26              | 6:00 PM  | AS      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 7/14/26              | 2:40 PM  | AH      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 7.4 SU   | 7.2 - 7.8 SU    | 7/13/26              | 9:30 AM  | SH      | DPD      |
| Chlorine:             | 1.0 mg/l | 1.0 - 5.0 mg/l  | 7/13/26              | 9:30 AM  | SH      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 7/13/26              | 9:30 AM  | SH      | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)